

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/09/2018  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>495197</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>02/19/2015</b>
NAME OF PROVIDER OR SUPPLIER  <b>BELVOIR WOODS HEALTH CARE CENTER AT THE FAIRFAX</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>9160 BELVOIR WOODS PKWY</b> <b>FORT BELVOIR, VA 22060</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>Description of structure: The facility occupies one floor of a three story building with a construction type of IIA.</p> <p>Sprinkler status: The facility is a fully sprinklered building.</p> <p>An unannounced recertification Life Safety Code revisit to the standard survey conducted on 1/21/2015 was conducted on 2/19/2015 in accordance with 42 Code of Federal Regulation, Part 483.70: Requirements for Long Term Care Facilities. The facility was surveyed for compliance using the 2000 Life Safety Code. The facility was in compliance with the Requirements for Participation Medicare and Medicaid.</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.